

## Moosa Rafey

---

**From:** Paul Bunevich  
**Sent:** Thursday, December 10, 2020 12:09 PM  
**To:** John Mack  
**Cc:** Mark Massoud; Roy Cavanaugh; Moosa Rafey  
**Subject:** Lot 5 - Caruso Drive - Watertown

John: The Subsurface Sewage Disposal System Plan submitted by your office for Inland Wetlands approval is lacking some key items which affect my review for the CCIWA.

I field walked the site this morning, and some existing drainage structures are not labeled, while at the western end of the 21" r.c.p. it appears a rerouting of the pipe outlet is proposed to remove the outlet from the Moher property, but no design plans have been submitted, which would require extensive E & SC and Water Handling Plans for work in and around the Lake.

I have been informed that the CCIWA wants to schedule a field walk of the site, so no action is anticipated on the application at tonight's meeting. Please submit any plans for the drainage work including pipe calcs., etc. so that I can complete my review for the January 2021 meeting.

Thanks  
Paul